

NUVOCO VISTAS CORPORATION LIMITED (FORMERLY LAFARGE INDIA LIMITED)

BHIWANI CEMENT PLANT

CHIRIYA VILLAGE, CHARKHI - DADRI MANDAL, BHIWANI DIST., HARYANA STATE

Monitoring Data for the Month of January' 2018

A. Stack Emission:

S.N.	Stack Attached to	Pollution Control Equipment	CPCB STD (Max.)	Particulate Matter* (Mg/NM ³)
01	Classifier Stack	Bag Filter	30 mg/NM ³	28.88
02	Packing Plant Stack - 1	Bag Filter	30 mg/NM ³	25.95
03	Packing Plant Stack - 2	Bag Filter	30 mg/NM ³	27.87

Note: * Spot test results, CEMS reading for: PM < 30 mg/NM³(Classifier)

B. Ambient Air Quality :

Pollutants	CPCB STD (Max.)	AAQ (Monthly Average) (All values in Microgram/M ³)		
		Ambient Air Quality Monitoring Stations		
		Main Gate	Near Packing Plant	Pump House
PM -10	100	96.03	89.50	94.43
PM -2.5	60	50.83	54.22	55.42
SO _x	80	9.06	10.21	8.85
NO _x	80	25.41	28.96	27.95
CO	2000	1.02	1.13	1.08
Noise level	75/70 dB(A)	Noise level is <75 dB(A) in Day time <65 dB(A) during Night time		

C. Discharge Water Quality : Quality of Treated water of Sewage Treatment Plant (STP)

S.N.	Pollutants	PCB Standard (Max)	Results obtained
1	p ^H	5.5-9.0	7.30
2	Suspended Solids	100 mg/Ltr	20.0
3	Chemical Oxygen Demand (COD)	250 mg/Ltr	87.48
4	Bio-Chemical Oxygen Demand (BOD)	30 mg/Ltr	26.25

STP water is used for Horticulture purpose.

R.K. Khamparia
Asst. Vice President.



Nuvoco Vistas Corp. Ltd.

(formerly Lafarge India Limited)

Bhiwani Cement Plant : Village Chirya, Teh. Charkhi Dadri, Dist. Bhiwani (Haryana) - 127022 (India).

Tel : +91 82959 44405 | Website : www.nuvoco.in | CIN-U26940MH1999PLC118229

Registered Office : Equinox Business Park, Tower-3, East Wing, 4th Floor, LBS Road, Kurla (West), Mumbai 400070