

NUVOCO VISTAS CORPORATION LIMITED (FORMERLY LAFARGE INDIA LIMITED)

BHIWANI CEMENT PLANT

CHIRIYA VILLAGE, CHARKHI - DADRI MANDAL, BHIWANI DIST., HARYANA STATE

Monitoring Data for the Month of SEPTEMBER' 2018

A. Stack Emission:

S.N.	Stack Attached to	Pollution Control Equipment	CPCB STD (Max.)	Particulate Matter* (Mg/NM ³)
01	Classifier Stack	Bag Filter	30 mg/NM ³	26.9
02	Packing Plant Stack - 1	Bag Filter	30 mg/NM ³	25.0
03	Packing Plant Stack - 2	Bag Filter	30 mg/NM ³	24.8

Note: * Spot test results, CEMS reading for: PM < 30 mg/NM³(Classifier)

B. Ambient Air Quality :

Pollutants	CPCB STD (Max.)	AAQ (Monthly Average) (All values in Microgram/ M ³)		
		Ambient Air Quality Monitoring Stations		
		Main Gate	Near Packing Plant	Pump House
PM -10	100	89.47	85.60	73.35
PM -2.5	60	50.21	48.65	43.44
SOx	80	7.85	8.10	7.10
NOx	80	25.37	26.47	22.74
CO	2000	790	880	720
Noise level	75/70 dB(A)	Noise level is <75 dB(A) in Day time <65 dB(A) during Night time		

C. Discharge Water Quality : Quality of Treated water of Sewage Treatment Plant (STP)

S.N.	Pollutants	PCB Standard (Max)	Results obtained
1	pH	5.5-9.0	7.30
2	Suspended Solids	100 mg/Ltr	19.00
3	Chemical Oxygen Demand (COD)	250 mg/Ltr	56.30
4	Bio-Chemical Oxygen Demand (BOD)	30 mg/Ltr	15.0

STP water is used for Horticulture purpose.



R.K. Khamparia
Vice President.



Nuvoco Vistas Corp. Ltd.

(formerly Lafarge India Limited)

Bhiwani Cement Plant : Village Chirya, Teh. Charkhi Dadri, Dist. Bhiwani (Haryana) – 127022 (India).

Tel : +91 82959 44405 | Website : www.nuvoco.in | CIN-U26940MH1999PLC118229

Registered Office : Equinox Business Park, Tower-3, East Wing, 4th Floor, LBS Road, Kurla (West), Mumbai 400070