


Jojobera Cement Plant
Environment Monitoring Data for the Month of June 2019

A. Stack Monitoring

S. No.	Stack Attached to	Bag Filter No.	Pollution Control Equipment	STD. (MAX) (Mg/NM ³)	Particulate Matter Actual (Mg/NM ³)
1	Slag Grinding	550BF2	Bag Filter	30	25.59
2	Slag Grinding	550BF4	Bag Filter	30	20.63
3	Slag Grinding	550BF6	Bag Filter	30	23.40
4	Slag Grinding	551BF2	Bag Filter	30	23.87
5	Slag Grinding	551BF4	Bag Filter	30	21.27
6	Slag Grinding	551BF6	Bag Filter	30	25.96
7	Slag Grinding	560BF1	Bag Filter	30	20.54
8	Clinker Grinding	565BF1	Bag Filter	30	20.50
9	Clinker Grinding	566BF1	Bag Filter	30	20.06
10	Clinker Grinding	567BF1	Bag Filter	30	23.80
11	Clinker Grinding	567BF2	Bag Filter	30	22.37
12	Clinker Grinding	568BF1	Bag Filter	30	20.91
13	Clinker Grinding	568BF2	Bag Filter	30	25.81
14	Clinker Grinding	570BF1	Bag Filter	30	20.71
15	Clinker Grinding	570BF2	Bag Filter	30	22.70
16	PPC II	571BF1	Bag Filter	30	23.81
17	PPC II	571BF2	Bag Filter	30	21.21
18	Packing Plant	661BF1	Bag Filter	30	26.76
19	Packing Plant	662BF1	Bag Filter	30	21.02
20	Packing Plant	663BF1	Bag Filter	30	25.72
21	VRM	456DC98	Bag House	30	27.72
22	Coal Mill	613DC14	Bag Filter	30	27.62



Sr. Vice President
 Jojobera Cement Plant

SR. VICE PRESIDENT 
 NUVOCO VISTAS CORP. LTD.
 JOJOBERA CEMENT PLANT
 P.O. - RAHARGORA
 JAMSHEDPUR - 831018

Jojobera Cement Plant
Environment Monitoring Data for the Month of June 2019

B. Ambient Air Quality

S. NO.	PARAMETER	UNIT	LIMIT	Auto Garage	300 KL LDO Tank	Railway Gate	Time Office	Material Gate
1	PM 10	ug/m3	100	90.73	88.74	86.82	88.33	83.69
2	PM 2.5	ug/m3	60	51.11	43.24	45.95	45.39	42.31
3	Sulphur Dioxide(SO ₂)	ug/m3	80	44.90	46.02	42.24	44.31	43.74
4	Nitrogen Dioxide(NO ₂)	ug/m3	80	40.11	40.49	40.58	38.25	42.60

C. STP Outlet Water Quality

S. No.	Pollutants	PCB Standard (Max)	Results obtained (STP outlet water)
1	pH	5.5 - 9.0	6.98
2	Total Suspended Solids (TSS)	100 mg/litre	9.0
3	Chemical Oxygen Demand (COD)	250 mg/litre	36.0
4	Biological Oxygen Demand (BOD)	30 mg/litre	10.0

D. Noise Monitoring Data

S.NO.	LOCATION	NOISE LEVELS	
		Day Time [Limit - 75 dB(A)]	Night Time [Limit - 70 dB(A)]
1	TIME OFFICE	70.92	66.69
2	RAILWAY GATE	71.03	65.99
3	300 KL LDO TANK	72.04	66.25



Sr. Vice President
Jojobera Cement Plant

SR. VICE PRESIDENT
NUVOCO VISTAS CORP. LTD.
JOJOBERA CEMENT PLANT
 P.O. - RAHARGORA
 JAMSHEDPUR - 831016