

**Jojobera Cement Plant**  
**Environment Monitoring Data for the Month of July 2019**

**A. Stack Monitoring**

S. No.	Stack Attached to	Bag Filter No.	Pollution Control Equipment	STD. (MAX) (Mg/NM <sup>3</sup> )	Particulate Matter Actual (Mg/NM <sup>3</sup> )
1	Slag Grinding	550BF2	Bag Filter	30	20.81
2	Slag Grinding	550BF4	Bag Filter	30	20.23
3	Slag Grinding	550BF6	Bag Filter	30	25.11
4	Slag Grinding	551BF2	Bag Filter	30	20.31
5	Slag Grinding	551BF4	Bag Filter	30	26.53
6	Slag Grinding	551BF6	Bag Filter	30	24.14
7	Slag Grinding	560BF1	Bag Filter	30	23.91
8	Clinker Grinding	565BF1	Bag Filter	30	16.65
9	Clinker Grinding	566BF1	Bag Filter	30	18.31
10	Clinker Grinding	567BF1	Bag Filter	30	26.61
11	Clinker Grinding	567BF2	Bag Filter	30	24.03
12	Clinker Grinding	568BF1	Bag Filter	30	19.48
13	Clinker Grinding	568BF2	Bag Filter	30	20.10
14	Clinker Grinding	570BF1	Bag Filter	30	20.62
15	Clinker Grinding	570BF2	Bag Filter	30	26.40
16	PPC II	571BF1	Bag Filter	30	Circuit shutdown
17	PPC II	571BF2	Bag Filter	30	Circuit shutdown
18	Packing Plant	661BF1	Bag Filter	30	25.71
19	Packing Plant	662BF1	Bag Filter	30	20.41
20	Packing Plant	663BF1	Bag Filter	30	22.06
21	VRM	456DC98	Bag House	30	23.20
22	Coal Mill	613DC14	Bag Filter	30	23.49



Sr. Vice President  
Jojobera Cement Plant  
Jojobera Cement Plant  
Nuvoco Vistas Corp. Ltd.  
Jamshedpur - 831 018  
Jharkhand

**Jojobera Cement Plant**  
**Environment Monitoring Data for the Month of July 2019**

**B. Ambient Air Quality**


S. NO.	PARAMETER	UNIT	LIMIT	Auto Garage	Near LDO Tank	Railway Gate	Time Office	Material Gate
1	PM 10	ug/m3	100	80.57	85.76	79.15	84.42	78.48
2	PM 2.5	ug/m3	60	41.43	43.63	39.25	43.50	34.08
3	Sulphur Dioxide(SO <sub>2</sub> )	ug/m3	80	40.03	38.86	40.68	39.74	40.91
4	Nitrogen Dioxide(NO <sub>2</sub> )	ug/m3	80	35.91	36.71	37.29	37.50	36.39

**C. STP Outlet Water Quality**

S. No.	Pollutants	PCB Standard (Max)	Results obtained (STP outlet water)
1	pH	5.5 – 9.0	6.96
2	Total Suspended Solids (TSS)	100 mg/litre	7.0
3	Chemical Oxygen Demand (COD)	250 mg/litre	17.0
4	Biological Oxygen Demand (BOD)	30 mg/litre	3.0

**D. Noise Monitoring Data**

S.NO.	LOCATION	NOISE LEVELS Day Time [ Limit - 75 dB(A)]	NOISE LEVEL Night Time [ Limit - 70 dB(A) ]
1	TIME OFFICE	60.79	57.13
2	RAILWAY GATE	71.32	67.03
3	LDO TANK	66.54	60.84

  
 Sr. Vice President  
 Jojobera Cement Plant  
 Jojobera Cement Plant  
 Nuvoco Vistas Corp. Ltd.  
 Jamshedpur - 831 018  
 Jharkhand