

INDIA

ARASMETA CEMENT PLANT OF M/S LAFARGE INDIA LTD.
VILLAGE ARASMETA, PO- GOPALNAGAR, DISTT.
JANJGIR - CHAMPA, CHHATTISGARH

CONSENT TO OPERATE

PLANT: - AIR Consent Letter No. 5204//TS/CECB/2016 dated 28/01/2016 for Cement 22.4 Lacs MT/Annum
Water Consent Letter No. 5202//TS/CECB/2016 dated 28/01/2016 for Cement 22.4 Lacs MT/Annum
D.G Set: - AIR Consent Letter No. 3386//TS/CECB/2016 date 09/09/2016 for 3 x 6 = 18 MW.
Water Consent Letter No. 3384//TS/CECB/2016 date 09/09/2016 for 3 x 6 = 18 MW

Monitoring Data For the Month of Sep` 2016

A. Stack Emission – Consent Condition for Particulate matter -Max. 50 mg/NM³

S.N.	Stack Attached to	PCEs	Particulate Matter (Mg/Nm ³)
1	KILN & RAW MILL -1	Bag Filter	24.3
2	PC & RAW MILL -2	Bag Filter	29.5
3	COOLER	ESP	26.8
4	COAL MILL -1	Bag Filter	21.9
5	COAL MILL -2	Bag Filter	24.3
6	CEMENT MILL -1	Bag Filter -1	25.2
7	CEMENT MILL -1	Bag Filter -2	28.3
8	CEMENT MILL -2	ESP	28.1
9	CEMENT MILL -2	Bag Filter	NR
10	DG-3	-	NR
11	DG-4	-	NR
12	DG-5	-	NR

SD-Shut down, NR- Not running

B. Ambient Air Quality –

Pollutants	Ambient Air Quality (Monthly Average)				
	LOCATION				
	NAAQ STD.	Near Wagon Tippler - East	Near Main Security Gate - West	Near Rail way TXR Office -North	Near Old Truck Tippler - South
PM10 (µg/m3)	100	57.0	55.0	52.0	48.0
PM2.5 (µg/m3)	60	34.0	32.0	30.0	26.0
Sulphur Dioxide SO2 (µg/m3)	80	7.9	7.1	6.6	6.5
Nitrogen Dioxide NO2 (µg/m3)	80	9.8	9.4	8.3	8.2
Carbon Monoxide CO (mg/m3)	4	0.17	0.16	0.15	0.14

C- Discharge Water Quality:

Cement plant maintained Zero Discharge, for cooling water close circuit arrangement, Plant domestic water discharge through Sock pit. Sewage Treatment Plant installed in colony for treatment of Domestic wastewater, Treated water used for Horticulture purpose.

Quality of Treated water of STP:

S.N.	Pollutants	Monthly average Results	CECB Standard (Max)
1	pH	7.7	5.5 - 9.0
2	Suspended Solids	84	100 mg/Ltr.
3	Chemical Oxygen Demand (COD)	68	250 mg/Ltr
4	Biological Oxygen Demand (BOD)	12	30 mg/Ltr
5	Oil& Grease	<5	10 mg/Ltr

For Lafarge India Limited,
(Arasmeta Cement Plant)


(Ramesh Chandra Pathak)
Vice President