

NUVOCO VISTAS CORPORATION LIMITED (FORMERLY LAFARGE INDIA LIMITED)

SONADIH CEMENT PLANT

P.O. RASEDA – 493332, DISTT.- BALODA BAZAR- BHATAPARA, CHHATTISGARH

ENVIRONMENTAL CLEARANCE

For Line 1 Letter No. F. No. J-11011/28/2002-IA-II (I) dated 23/10/2002 & letter dtd 30/12/2002 & 03/06/2004 and for expansion of Cement Plant from 1.50 to 3.50 MPTA (Phase-2) F.No.J-11011/386/2005-IA-II (I)dated 16/03/2006 & Amendment letter dtd 05/05/2006

Monitoring Data for the Month of April 2017

A . Stack Emission:

S.N.	Stack Attached to		Pollution Control	CECB STD	Particulate Matter*
S.IV.	Stack Attact	led to	Equipment	(Max.)	(Mg/NM3)
01	Kiln & Raw mill	(Line1)	Hybrid Filter	30 mg/NM ³	21
02	Kiln & Raw mill	(Line 2)	Bag House	30 mg/NM ³	18
03	Clinker cooler	(Line1)	ESP	30 mg/NM ³	24
04	Clinker cooler	(Line 2)	Bag house	30 mg/NM ³	17
05	Coal mill	(Line1)	Bag Filter	30 mg/NM ³	22
06	Coal mill	(Line 2)	Bag Filter	30 mg/NM ³	20
07	Cement mill		Bag Filter	30 mg/NM ³	20
08	Lime stone crush	ner	Bag Filter	30 mg/NM ³	17

Note: * Spot test results, CEMS reading for: PM < 30 mg/NM³ NOx < 800 mg/NM⁻SO2 < 100 mg/NM³

B. Ambient Air Quality:

		AAQ (Monthly Average) (All values in Microgram/M³) Ambient Air Quality Monitoring Stations				
Pollutants	CECB STD					
Foliularits	(Max.)	Near Time	Near LS	Near Material	Near Scrap	
Anama II		office	Crusher	Gate	yard	
PM -10	100	68.9	74	83.4	71.6	
PM -2.5	60	36.3	36.4	45.0	37.8	
SOx	80	8.2	14.8	19.4	6.6	
NOx	80	6.5	12.1	14.1	5.5	
CO	2000	<10	214	1606	402	
Noise level	75/70 dB(A)	Noise level is <70 dB(A) in Day time				
		<65 dB(A) during Night time				

C. <u>Discharge Water Quality</u>: Quality of Treated water of Sewage Treatment Plant (STP)

S.N.	Pollutants	PCB Standard (Max)	Results obtained	
1	P	5.5-9.0	7.4	
2	Suspended Solids	100 mg/Ltr	63	
3	Chemical Oxygen Demand (COD)	250 mg/Ltr	84	
4	Bio-Chemical Oxygen Demand (BOD)	30 mg/Ltr	13	

STP water is used for Horticulture purpose.

Sanjay Joshi

Sr.Vice President

Nuvoco Vistas Corp. Ltd. (formerly Lafarge India Limited)

Sonadih Cement Plant, PO: Raseda, Dist.: Balodabazar-Bhatapara, Raipur – 493332 (India).

Website: www.nuvoco.in | CIN-U26940MH1999PLC118229

Registered Office: Equinox Business Park, Tower-3, East Wing, 4th Floor, LBS Road, Kurla (West), Mumbai 400070