


Jojobera Cement Plant
Environment Monitoring Data for the Month of July, 2017

A. Stack Monitoring

S. No.	Stack Attached to	Bag Filter No.	Pollution Control Equipment	STD. (MAX) (Mg/NM ³)	Particulate Matter Actual (Mg/NM ³)
1	Slag Grinding	550BF2	Bag Filter	30	19.64
2	Slag Grinding	550BF4	Bag Filter	30	28.79
3	Slag Grinding	550BF6	Bag Filter	30	23.57
4	Slag Grinding	551BF2	Bag Filter	30	28.33
5	Slag Grinding	551BF4	Bag Filter	30	21.65
6	Slag Grinding	551BF6	Bag Filter	30	28.09
7	Slag Grinding	560BF1	Bag Filter	30	23.25
8	Clinker Grinding	565BF1	Bag Filter	30	22.48
9	Clinker Grinding	566BF1	Bag Filter	30	19.78
10	Clinker Grinding	567BF1	Bag Filter	30	26.68
11	Clinker Grinding	567BF2	Bag Filter	30	25.83
12	Clinker Grinding	568BF1	Bag Filter	30	25.65
13	Clinker Grinding	568BF2	Bag Filter	30	18.98
14	Clinker Grinding	570BF1	Bag Filter	30	27.90
15	Clinker Grinding	570BF2	Bag Filter	30	15.44
16	PPC II	571BF1	Bag Filter	30	14.32
17	PPC II	571BF2	Bag Filter	30	14.08
18	Packing Plant	661BF1	Bag Filter	30	25.50
19	Packing Plant	662BF1	Bag Filter	30	19.90
20	Packing Plant	663BF1	Bag Filter	30	20.89
21	VRM	456DC98	Bag House	30	22.89
22	Coal Mill	613DC14	Bag Filter	30	12.69



(Manoj Kumar Agrawal)
Vice President
Jojobera Cement Plant

Jojobera Cement Plant
Environment Monitoring Data for the Month of July, 2017

B. Ambient Air Quality

Sampling Location 1 : Railway Over Bridge

S.NO.	PARAMETER	UNIT	LIMIT	RESULT
1	Sulphur Dioxide(SO ₂)	ug/m3	80	65.08
2	Nitrogen Dioxide(NO ₂)	ug/m3	80	42.64
3	PM 10	ug/m3	100	75.68
4	PM 2.5	ug/m3	60	46.22

Sampling Location 2 : Near Material Gate

S.NO.	PARAMETER	UNIT	LIMIT	RESULT
1	Sulphur Dioxide(SO ₂)	ug/m3	80	59.21
2	Nitrogen Dioxide(NO ₂)	ug/m3	80	42.29
3	PM 10	ug/m3	100	71.59
4	PM 2.5	ug/m3	60	47.91

Sampling Location 3 : Near Time Office

S.NO.	PARAMETER	UNIT	LIMIT	RESULT
1	Sulphur Dioxide(SO ₂)	ug/m3	80	55.28
2	Nitrogen Dioxide(NO ₂)	ug/m3	80	40.14
3	PM 10	ug/m3	100	76.23
4	PM 2.5	ug/m3	60	38.83



(Manoj Kumar Agrawal)
Vice President
Jojobera Cement Plant

