

ARASMETA CEMENT PLANT OF M/S NUVOCO VISTAS CORP.LTD.
VILLAGE ARASMETA, PO- GOPALNAGAR, DISTT.
JANJGIR - CHAMPA, CHHATTISGARH

CONSENT TO OPERATE

PLANT: - AIR Consent Letter No. 3454/TS/CECB/2018 dated 23/07/2018 for Cement 22.4 Lacs MT/Annum
Water Consent Letter No. 3452/TS/CECB/2018 dated 23/07/2018 for Cement 22.4 Lacs MT/Annum
D.G Set: - AIR Consent Letter No. 3386/TS/CECB/2016 date 09/09/2016 for 3 x 6 = 18 MW.
Water Consent Letter No. 3384/TS/CECB/2016 date 09/09/2016 for 3 x 6 = 18 MW

Monitoring Data For the Month of Oct` 2018

A. Stack Emission – Consent Condition for Particulate matter -Max. 30 mg/Nm³

S.N.	Stack Attached to	PCEs	Particulate Matter (Mg/Nm ³)
1	KILN & RAW MILL -1	Bag Filter	23.2
2	PC & RAW MILL -2	Bag Filter	BD
3	COOLER	ESP	BD
4	COAL MILL -1	Bag Filter	NR
5	COAL MILL -2	Bag Filter	24.1
6	CEMENT MILL -1	Bag Filter -1	SD
7	CEMENT MILL -1	Bag Filter -2	SD
8	CEMENT MILL -2	ESP	26.7
9	CEMENT MILL -2	Bag Filter	26.3
10	DG-3	-	NR
11	DG-4	-	NR
12	DG-5	-	NR

SD-Shut down, NR- Not running

B. Ambient Air Quality –

Pollutants	Ambient Air Quality (Monthly Average)				
	LOCATION				
	NAAQ STD.	Near Wagon Tippler - East	Near Main Security Gate - West	Near Rail way TXR Office -North.	Near Old Truck Tippler (Near Petrol Pump) - South
PM10 (µg/m3)	100	21.5	25.4	24.4	22.3
PM2. 5 (µg/m3)	60	17.9	16.2	21.2	16.3
Sulphur Dioxide SO2 (µg/m3)	80	14.1	13.8	13.3	13.5
Nitrogen Dioxide NO2 (µg/m3)	80	17.4	16.2	15.2	16.5
Carbon Monoxide CO (mg/m3)	4	0.23	0.25	0.21	0.26

C- Discharge Water Quality:

Cement plant maintained Zero Discharge, for cooling water close circuit arrangement, Plant domestic water discharge through Sock pit. Sewage Treatment Plant installed in colony for treatment of Domestic wastewater, Treated water used for Horticulture purpose.

Quality of Treated water of STP:

S.N.	Pollutants	Monthly average Results	CECB Standard (Max)
1	pH	7.4	5.5 - 9.0
2	Suspended Solids	69	100 mg/Ltr.
3	Chemical Oxygen Demand (COD)	54	250 mg/Ltr
4	Biological Oxygen Demand (BOD)	22	30 mg/Ltr
5	Oil& Grease	<5	10 mg/Ltr

For Nuvoco Vistas Corp.Ltd (Formerly Lafarge India Ltd)
(Arasmeta Cement Plant)

(Anil Sharma)

Asst. Vice President -ACP

Nuvoco Vistas Corp. Ltd.

(formerly Lafarge India Limited)

Arasmeta Cement Plant, P.O. Gopalnagar, Dist. Janjgir – Champa, Chhattisgarh – 495663 (India)

Website: www.nuvoco.in | CIN. U26940MH1999PLC118229

Registered Office: Equinox Business Park, Tower.3, East Wing, 4th Floor, LBS Road, Kurla (West), Mumbai 400070