

NUVOCO VISTAS CORPORATION LIMITED

BHIWANI CEMENT PLANT

VILLAGE CHIRIYA, DIST. CHARKHI - DADRI, STATE HARYANA

Monitoring Data for the Month of June' 2019

A. Stack Emission:

S.N.	Stack Attached to	Pollution Control Equipment	CPCB STD (Max.)	Particulate Matter* (Mg/NM ³)
01	Classifier Stack	Bag Filter	30 mg/NM ³	28.52
02	Packing Plant Stack - 1	Bag Filter	30 mg/NM ³	26.14
03	Packing Plant Stack - 2	Bag Filter	30 mg/NM ³	25.72

Note: * Spot test results, CEMS reading for: PM < 30 mg/NM³(Classifier)

B. Ambient Air Quality:

Pollutants	CPCB STD (Max.)	AAQ (Monthly Average) (All values in Microgram/M ³)		
		Ambient Air Quality Monitoring Stations		
		Main Gate	Near Packing Plant	Pump House
PM -10	100	94.83	88.69	94.55
PM -2.5	60	53.40	49.78	55.43
SOx	80	11.47	13.28	10.65
NOx	80	26.54	24.51	26.94
CO	2000	970	930	1580
Noise level	75/70 dB(A)	Noise level is <75 dB(A) in Day time <65 dB(A) during Night time		

C. Discharge Water Quality: Quality of Treated water of Sewage Treatment Plant (STP)

S.N.	Pollutants	PCB Standard (Max)	Results obtained
1	pH	5.5-9.0	7.75
2	Suspended Solids	100 mg/Ltr	35.0
3	Chemical Oxygen Demand (COD)	250 mg/Ltr	80.54
4	Bio-Chemical Oxygen Demand (BOD)	30 mg/Ltr	29.42

STP water is used for Horticulture purpose.

R.K. Khamparia
R.K. Khamparia
 Vice President.