


Jojobera Cement Plant
Environment Monitoring Data for the Month of November 2020

A. Stack Monitoring

S. No.	Stack Attached to	Bag Filter No.	Pollution Control Equipment	STD. (MAX) (Mg/NM ³)	Particulate Matter Actual (Mg/NM ³)
1	Slag Grinding	550BF2	Bag Filter	30	27.11
2	Slag Grinding	550BF4	Bag Filter	30	27.63
3	Slag Grinding	550BF6	Bag Filter	30	28.53
4	Slag Grinding	551BF2	Bag Filter	30	28.18
5	Slag Grinding	551BF4	Bag Filter	30	25.83
6	Slag Grinding	551BF6	Bag Filter	30	28.09
7	Slag Grinding	560BF1	Bag Filter	30	23.79
8	Clinker Grinding	565BF1	Bag Filter	30	28.85
9	Clinker Grinding	566BF1	Bag Filter	30	27.57
10	Clinker Grinding	567BF1	Bag Filter	30	27.10
11	Clinker Grinding	567BF2	Bag Filter	30	24.91
12	Clinker Grinding	568BF1	Bag Filter	30	26.81
13	Clinker Grinding	568BF2	Bag Filter	30	23.18
14	Clinker Grinding	570BF1	Bag Filter	30	27.76
15	Clinker Grinding	570BF2	Bag Filter	30	28.45
16	PPC II	571BF1	Bag Filter	30	28.89
17	PPC II	571BF2	Bag Filter	30	27.24
18	Packing Plant	661BF1	Bag Filter	30	27.89
19	Packing Plant	662BF1	Bag Filter	30	27.81
20	Packing Plant	663BF1	Bag Filter	30	22.69
21	VRM	456DC98	Bag House	30	28.27
22	Coal Mill	613DC14	Bag Filter	30	23.48



(Raju Ramchandran)

Sr. Vice President (Jojobera Cement Plant)

di.

Jojobera Cement Plant
Environment Monitoring Data for the Month of November 2020

B. Ambient Air Quality


S. NO.	PARAMETER	UNIT	LIMIT	Auto Garage	Near Gypsum Yard	Railway Gate	Time Office	Material Gate
1	PM 10	ug/m3	100	96.35	99.58	88.27	84.43	93.35
2	PM 2.5	ug/m3	60	55.24	52.74	43.42	41.01	48.34
3	Sulphur Dioxide(SO ₂)	ug/m3	80	34.23	33.59	34.40	31.42	33.65
4	Nitrogen Dioxide(NO ₂)	ug/m3	80	46.90	45.67	48.93	43.93	48.32

C. STP Outlet Water Quality

S. No.	Pollutants	PCB Standard (Max)	Results obtained (STP outlet water)
1	pH	5.5 – 9.0	7.85
2	Total Suspended Solids (TSS)	100 mg/litre	23.0
3	Chemical Oxygen Demand (COD)	250 mg/litre	10.0
4	Biological Oxygen Demand (BOD)	30 mg/litre	<2.0

D. Noise Monitoring Data

S.NO.	LOCATION	NOISE LEVELS Day Time [Limit - 75 dB(A)]	NOISE LEVEL Night Time [Limit - 70 dB(A)]
1	TIME OFFICE	72.73	61.03
2	RAILWAY GATE	73.28	62.26
3	GYPSUM YARD	73.33	62.53



(Raju Ramchandran)

Sr. Vice President (Jojobera Cement Plant)